



REPLY TO  
ATTENTION OF

**DEPARTMENT OF THE ARMY**  
**US ARMY INSTALLATION MANAGEMENT COMMAND**  
**HEADQUARTERS, US ARMY GARRISON, CARLISLE BARRACKS**  
**22 ASHBURN DRIVE**  
**CARLISLE, PENNSYLVANIA 17013-5000**

IMNE-CLB-PWE

12 August 2011

MEMORANDUM FOR SEE DISTRIBUTION

SUBJECT: Addendum to Annual Drinking Water Quality Report, PWSID 7210010, at Carlisle Barracks, PA, 1 January to 31 December 2010

1. References:

a. Annual Drinking Water Quality Report, PWSID 7210010, at Carlisle Barracks, PA, 1 January to 31 December 2010, dated 4 May 2011.

b. AR 200-1, Environmental Protection and Enhancement, 13 December 2007; Safe Drinking Water Act (SDWA) (35 P.S. §721.1 et seq.) and regulations at Title 25 Pa. Code Chapter 109.

2. In accordance with AR 200-1, para 4-2f(a), the drinking water policy provides drinking water to fixed facilities in accordance with the requirements of SDWA and applicable state and local regulations.

3. Pennsylvania Department of Environmental Protection requested addition of information in this addendum to the Annual Drinking Water Quality Report, PWSID 7210010, at Carlisle Barracks, PA, 1 January to 31 December 2010.

4. This addendum is to the Annual Drinking Quality Report referenced in para 1a.

Contaminant	MRDL	MRDLG	Level Detected	Range of Detection	Violation	Sources of Contamination
Chlorine	4	4	0.5	0.1 – 0.5 ppm	No	Water additives used to control microbes

*Maximum Residual Disinfection Level (MRDL)* – The highest level of a disinfectant allowed in drinking water.

*Maximum Residual Disinfection Level Goal (MRDLG)* – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

IMNE-CLB-PWE

SUBJECT: Addendum to Annual Drinking Water Quality Report, PWSID 7210010, at Carlisle Barracks, PA, 1 January to 31 December 2010

*Parts per Million (ppm) or Milligrams per Liter (mg/L)* – one part per million corresponds to one minute in two years or a single penny in \$10,000.

5. If you have questions regarding this report, please contact Ms. Donna Swauger, Environmental Protection Specialist, at ext. 53908 or [donna.swauger@us.army.mil](mailto:donna.swauger@us.army.mil).



THOMAS J. KELLY  
Director, Public Works

DISTRIBUTION:  
DPW Website  
File